

Information submitted on your septic system application becomes part of the public records of Gulf County. It must comply with Florida statutes and rules. The following check list will assist you in determining that your application meets all requirements. (References: Chapter 64E-6, Fla. Administrative Code; Sec. 381.0065, Florida Statutes.)

Required Data

Copy of site plan, plat or survey, or map **drawn to scale** showing:

1. Boundaries with dimensions.
2. Slope of land.
3. Location of building(s).
4. Location of septic tank and drainfield.
5. Location of potable water lines.
6. Location of well or other water source on property.
7. Location of septic tank, drainfield, and well on adjacent properties (side, front, and rear).
8. Location of storm water retention pond and other drainage structures.
9. Location of driveway.
10. Location of pools or other obstructions.

In addition to the setbacks, the lot or parcel **must meet one** of the following criteria:

1. Net area of $\frac{1}{4}$ acre with public water supply. Projected sewage flow may not exceed 2,500 gallons per acre, per day.
2. Net area of $\frac{1}{2}$ acre if well and septic tank are used. Projected sewage flow may not exceed 1,500 gallons per day.
3. Lots platted prior to January 1, 1972, are exempt from net acreage requirements, but must comply with maximum daily sewage flow restrictions.

NOTE: Net area is that portion free of encumbrances such as paved areas and prepared road beds within public right-of-way easements, streams, lakes, drainage, marshes, or other bodies of surface water.

If there is any questions as to whether the lot meets these requirements, the burden of proof lies with the applicant.

GULF COUNTY HEALTH DEPARTMENT